

LEONI Kerpen GmbH · Postfach 1520 · D-52203 Stolberg

Psiber Data GmbH
Thomas Huesch
Felix-Wankel-Strasse 4
82152 Krailling (Munich)

07-Nov.-2011

Subject: Psiber Data WireXpert™ Approval

Dear Thomas,
Effective immediately, Leoni-Kerpen is pleased to announce the approval of the WireXpert WX4500-FA. This approval is based upon evaluation of the WireXpert versus network analyzer by Leoni-Kerpen Labs.

WireXpert is approved for use in both Permanent Link and Channel certification testing with all of our Class FA, Class F, Category 6A/Class EA, Category 6/Class E and Category 5e/Class D system warranties.

For Class FA systems, the approval includes all parameters to the frequency range of 1000MHz. WireXpert measurements above 1000MHz were also found to have good correlation with network analyser, and can be used for information.

The following configuration of WireXpert is required.

WX4500 software version 3.9 or higher
ReportXpert™ software version 3.9 or higher

Channel testing for Class FA, Class F	WX_AD_TERACH2 – pair of TERA channel adapters
Permanent Link testing for Class FA, Class F	WX_AD_TERAL2 – pair of TERA Permanent Link adapters
Channel testing for Category 6A/Class EA, Category 6/Class E and Category 5e/Class D	WX_AD_6ACH2 - pair of CAT 6A channel adapters
Permanent Link testing for Category 6A/Class EA, Category 6/Class E and Category 5e/Class D	WX_AD_6ALKIT2 – pair of CAT 6A permanent link kits: each consisting of a CAT 6A permanent link adapter WX_AD_6ALINK and a Permanent Link test cord WX_AC_6ALCORD

Best regards



Thomas Opfermann
Produktmanager Kupfersysteme Datacom

LEONI Kerpen GmbH Zweifaller Straße 275-287
D-52224 Stolberg
Telefon +49 (0)2402-17-1
Telefax +49 (0)2402-75154
E-Mail info@leoni-kerpen.com
www.leoni-kerpen.com

Gesellschaft mit
beschränkter Haftung
Sitz Stolberg
Amtsgericht Aachen HRB 14131
USt-IDNr.: DE814817561

Vorsitzender des Aufsichtsrats:
Dr. Klaus Probst
Geschäftsführer:
Martin Moser
Wolfgang Schuh